

	12.12.2023
Opprettet av:	
Prosjektnummer:	
Prosjekt:	
Kunde:	
Prosjektleder:	

Declaration of exemption pursuant to §27-12 of the Norwegian Pollution Control Regulations.

Datasenter 1, Gromstul

Farm and lot number 11/28

UTM 32N East 529482 North 6570254


Regarding the application for a permit for a new polluting activity for Data Center 1 at Gromstul, it is assumed that the emergency power units are covered by Chapter 27 of the Pollution Control Regulations – Emissions to air from medium-sized combustion plants. Based on the generators' purpose as emergency power supply in the event of a possible power failure, it is relevant to use the exemption from the emission limit values because the plant is not intended to operate more than 500 hours per year.

The undersigned of this declaration is responsible for ensuring that the emergency power units at Data Center 1 will not exceed 500 operating hours per year.

WS Computing AS

City: Madrid

Date: 13-Dec-2023

DocuSigned by:
Sign: 
E48ADD2E0060465...

Name: Paul Henry

Title: EMEA Director